



## Procedures and Guidelines For Compressed Air Leak Assessments

The following information outlines the recommended procedures and guidelines for a **Compressed Air Leak Assessment Preliminary Assessment** under FY19 SRP Business Solutions Custom Program. Information in this document is designed to provide a basis of standard expectation from a compressed air leak assessment funded by FY19 SRP Business Solutions Custom Program. Compliance with this document will help address any particular configuration and performance requirement of a compressed air leak assessment. Where appropriate, industry specific leak assessment procedures should be used. All test results and deliverables should be reviewed carefully before submittal to SRP to ensure that they are complete and accurate.

### Overview

Under the program, the leak assessment must:

1. Document the existing inventory of active air compressors, including the following criteria:
  - o Size (HP)
  - o Capacity (SCFM)
  - o Capacity Control (e.g. load/no load, inlet modulation, variable displacement, variable speed, etc.)
  - o Discharge Pressure
2. Document the location and flow rate of each compressed air leak.
3. Compile leak assessment results in a predetermined report format in order to provide the Customer an estimate of the potential energy and demand savings and implementation cost for the recommended leak repair activities.

### Compressed Air Leak Assessment

The leak assessment is intended to collect compressed air leakage from pressurized compressed air systems. Field data should be collected with calibrated leak detection tools. Field data as collected during the leak assessment must be reliable in order to maintain the quality and accuracy of the energy savings. Collected data, such as decibels, must be appropriately logged and recorded for savings validation.

### Compressed Air Leak Assessment Equipment

In order to evaluate the total leak rate of a compressed air system, the supply side, distribution, and end uses must be sufficiently evaluated with appropriate equipment. Industry standard ultrasonic leak detection equipment and necessary probes should be used to record the decibels of the identified leak. The approximate air pressure at each leak location should be noted in order to estimate the respective leak rate (SCFM) accurately. The test equipment should be capable of collecting, holding, and saving field measured data electronically for later review and use.

### Deliverable & Documentation

The QSP will be required to complete a Preliminary Assessment Report in the SRP defined format. A template of this report will be provided to approved Compressed Air Leak Assessment QSPs. The report is prepopulated with basic program information and contains an embedded calculation tool that will work for many applications and is in place to minimize the QSP's time requirement in completing the report. The QSP would need to populate the inputs of this calculation tool using the field test data, provide existing compressed air system description along with recommendations for potential system improvements within the report. The QSP may choose to use any other calculation tool, provided that a copy of the analysis file is made available as part of the deliverables to the Program Administrator for review and approval.

The QSP must deliver a completed Compressed Air Leak Assessment report to the Program Administrator. The QSP will not be submitting the report to the Customer at any point. Upon SRP's review and approval, the Program Administrator will facilitate the assessment results to the customer.

Supporting photographs should be collected while on site and provided in the report's appendix.